



Permit #
Date Issued

DIGITAL ALARM COMMUNICATOR TRANSMITTERS (DACT) UTILIZING MANAGED FACILITY VOICE NETWORKS (MFVN) VERIFICATION FORM

IDENTIFICATION

Work Site Location _____ Block _____ Lot _____ Qualification Code _____

Owner in Fee _____ Contractor _____

Address _____ Address _____

Tel. (____) _____

Tel. (____) _____

License/Certification No. _____

Federal Emp. ID No. _____

Compliance Checklist

When a DACT's means of transmission is converted from Plain Old Telephone Service (POTS) to Managed Facility Voice Network (MFVN) Service, this checklist is to be completed by the licensed/certified alarm service provider and submitted to the Fire Protection Subcode Official of the Local Enforcing Agency within 24 hours of conversion.

DACT connected to qualified MFVN service

MFVN Provider Name and Telephone no.

DACT telephone circuit(s) configured and tested for loop start.

DACT telephone circuit(s) configured and tested for line seizure.

Minimum 8-hour standby battery installed and tested in MFVN communications equipment.

MFVN communications equipment installed at the protected premises with safeguards to prevent unauthorized access.

DACT alarm, trouble and supervisory signal transmission retested to Supervising Station successfully.

Alarm Service Provider name and telephone no.

Supervising Station Service Provider Name and Telephone no.

Signature

Date